



Germanischer Lloyd

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No. 42 737 - 02 HH

Company FOGTEC Brandschutz GmbH & Co. KG
Schanzenstraße 19 A
51063 Köln, GERMANY

Product Description High-Pressure Water-Based Fixed Fire Extinguishing System for Machinery Spaces and Cargo Pump Rooms (FSS Code Chapter 7/2.2)

Type FOGTEC Machinery Space System

Environmental Category None

Technical Data / Range of Application RANGE OF APPLICATION:
Water mist system for category A machinery spaces and cargo pump rooms each up to 1711 m³ net volume with a ceiling height not exceeding 7.5 m.
Bilges of less than 0.75 m height are to be fitted with a separate fire extinguishing system, e.g. low-expansion foam system.

TECHNICAL DATA: see page 2

Test Standard IMO MSC/Circ. 668/728

Documents See page 2

Remarks This certificate is valid together with our approval certificate No. 42938-02 HH.

Valid until 2010-06-10

Page 1 of 3


Type Approval Symbol




File No. II.H.01

Hamburg, 2007-06-27

Germanischer Lloyd


Günter Hölzer


Michael Kämpf

This certificate is issued on the basis of 'Guidelines for the Performance of Type Approvals Part 1, Procedure'.